

# Optimization of the DUSEL Beam Design

## DUSEL Beamline Working Group Mtg, 2/26/09

Mary Bishai  
Brookhaven National Lab

February 25, 2009

## Optimization of the DUSEL Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

- 1 Motivation
- 2 Focusing system optimization
- 3 Decay Pipe Optimization
- 4 Reducing HE tails
- 5 Beam Energy Impact
- 6 Physics impact of latest beam designs
- 7 Summary and Conclusions

# Searching for $\nu_\mu \rightarrow \nu_e$ in WCC

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization



Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

Using the 2007 DUSEL beam design and a parameterized simulation based on SuperK response for  $\sin^2(2\theta_{13}) = 0.02$  after 3 MW.yr:



Can we increase the flux in the 1-7 GeV region?

Can we reduce NC bkgd by improving beam design?

# Beam design strategies for DUSEL

## Optimization of the DUSEL Beam Design

Mary Bishai  
Brookhaven  
National Lab

## Motivation

Focusing  
system  
optimization


Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



- **Strategy 1:** Increase low energy flux at the oscillation maximum through improved:
  - 1a) target design
  - 1b) focusing
  - 1c) beam energy
  - 1d) decay pipe geometry
- **Strategy 2:** Improve S:B at low energies by reducing high energy tail using:
  - 2a) beam plugs,
  - 2b) off-axis beams
  - 2c) beam energy

— Needs work — 50-80% done — > 80% done —

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

# Focusing system optimization

# Optimization of target/focusing system design

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs


Summary and  
Conclusions

**Optimize focusing to maximize  $\nu_\mu$  flux at 1st and 3rd**

**oscillation maximum using NuMI-like horns**


**Insert CC target ( $r=6\text{mm}, L=80\text{cm}, \rho = 2.1 \text{ g/cm}^3$ ) into NuMI Horn1**

*Target and Horn 1 - Top View*



Default NuMI target/fin/baffle

*Target and Horn 1 - Top View*



New denser target, all the way in

**Fully embedding the target into the NuMI horns is the most optimal**

# Optimizing horn alignment

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails


Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

## *1-Decrease separation between Horn1 and Horn2 (fully embedded target)*

DUSEL event rates with different horn/target configs



**Moving the horns closer increases the low energy flux**

# Optimizing the horn currents

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

Simulated “perfect” focusing by setting hadron  $p_t = 0$ ,  $p_z = p_{\text{tot}}$  at production point from target surface and using GEANT to propagate hadrons through the beamline.

With an 80cm target fully embedded in NuMI horn1,  $\nu_\mu$  rates at 1300km with realistic/perfect focusing are:

Focusing efficiency of NuMI horns with fully embedded target



**250 kA horn current for NuMI style horns is best.**

**Can the low energy focusing efficiency be improved?**



Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions


# Decay pipe optimization

# Decay pipe length optimization

Current choice for decay pipe diameter = 4m

## Optimize decay pipe length:

DUSEL event rates with different decay pipe sizes



DP length	Rate 0 – 2 GeV	Rate 2 – 6GeV	Rate > 6GeV
180m	3.1	11	6.3
280m	3.5	14	8.1
<b>380m</b>	<b>3.6</b>	<b>16</b>	<b>9.7</b>
480m	3.7	17	11
580m	3.7	17	11

# Decay pipe shape optimization

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization


Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions


FD neutrino production vertex,  $E(\nu) < 2 \text{ GeV}$



FD neutrino production vertex,  $2 < E(\nu) < 6 \text{ GeV}$



FD neutrino production vertex,  $E(\nu) > 6 \text{ GeV}$



**Reduce volume by using conical shapes – See work by Byron Lundberg**

# Helium in the Decay Pipe

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

- The decay pipe is the single most expensive element in the beamline. An evacuated DUSEL decay pipe would increase costs considerably.
- To reduce costs, the design will be for a He filled decay pipe at  $\sim 1$  atm.
- He in the decay pipe acts as an absorber - esp for lower energy hadrons, in addition you can get extra HE  $\nu$  from proton beam remnant interactions with He.

**We need to assess the impact of He in the DUSEL decay pipe**

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization


Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

NuMI/MINOS ran Jan 25, 2005- August 2007 with an evacuated decay pipe (0.4 Torr). In September 2007, filled with He at 682.6 Torr (0.9atm).



**MINOS data: 2-3% increase in HE tails with He**

**DUSEL: This effect is dependant on decay pipe geometry**

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

# The Tale of HE Tails

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization


Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



Sensitivity with std background, 10% uncertainty

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization


Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



Sensitivity with 1/2 background, 10% uncertainty



Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization


Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



Sensitivity with default background, 10% uncertainty, double  $\bar{\nu}$  exposure

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

*For CPV sensitivity*

**$1/2$  background  $\sim \bar{\nu}$  exposure  $\times 2 \equiv 3$  MW.yrs**

# NC backgrounds in the MINOS ND Data



In the **MINOS ND data** we measured the background composition of  $\nu_e$  selected events with horn on/off in the region 1-8 GeV.

**SEE MAYLY SANCHEZ's W&C TALK TOMMOROW .**

$$\frac{\text{NC from tails}}{\text{All NC}} \sim \frac{\text{NC horn off}}{\text{NC horn on}} \sim 0.5 - 0.6$$

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization



Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



**MINOS data 20% more HE  $\nu$ s compared to Fluka05 MC**


# Whats a beam “plug”?



In 2001, Brett Viren (following up on studies at IHEP) found that a 1.5cm radius graphite target placed between the 2 horns reduced the high energy tails in NuMI LE beam by  $> 30\%$ .

# Adding plugs to NuMI/DUSEL

## Simulation of a plug in the DUSEL beamline



# DUSEL spectra with different plugs

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization


Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

DUSEL spectrum NuMI horns, embedded target, 250 kA at 1300km



FD DUSEL spectrum with beam plug/no plug




**With 1.5m plug**

$$\frac{\text{plug}}{\text{no plug}} (> 5\text{GeV}) = 0.62$$

$$\frac{\text{plug}}{\text{no plug}} (< 5\text{GeV}) = 0.99$$

# Enhanced production of $\bar{\nu}$ , $\nu_e$ with plug

ND DUSEL flux 1.5m Plug/No Plug



**$\bar{\nu}$  contamination in the  $\nu$  beam  $< 3$  GeV increases by 10%**

**$\nu_e + \bar{\nu}_e$  contamination in the  $\nu$  beam  $< 5$  GeV increases by 6%**



# Beam plugs Pros and Cons


### Pros:

- Most effective tool that reduces the HE flux exactly where you need it  $> 5$  GeV without any impact at low energy.
- Might give you more  $\nu$  at very low energies  $< 0.5$  GeV - good for solar oscillations.
- Tunable - different plugs can be used.

**Cons:**

- Requires expensive material R&D and engineering
- Complicates operating - need to change out plugs.
- Complicates beamline geometry for Near-Far extrapolation

**Another alternative to cutting down the high energy tails is going off-axis - redo calculation with optimized on-axis beam:**



**On axis flux is best for broad-band coverage**

# Off-Axis Pros and Cons

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

## Pros:

- Effective at reducing HE tails.
- At high angles  $> 1^\circ$  enhances flux at the 2nd oscillation maxima.
- NuMI/MiniBoone data confirms simulation predictions off-axis


## Cons:

- Throwing away beam flux at 1st osc maximum
- Limited tunability - WE CANT MOVE THE BEAMLINER!
- Limited broad-band spectrum.

# Impact of primary proton energy on spectrum

Optimize the primary proton beam power using “PERFECT” focusing (no horns, set all hadron  $p_T = 0$ ).

Effect of proton beam energy with perfect focusing



**Lowering the beam energy is very effective at reducing HE tails**  
**and increases flux at lower beam energies**  
**BUT must not sacrifice power!**

# FD spectra with latest optimization

**Embedded CC target in NuMI horns with 6m separation, cylindrical decay pipe with 4m diameter, 380m length, 120 GeV beam.**

## Optimization of the DUSEL Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization


Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

### Old DUSEL design



### New design



## Optimization of the DUSEL Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization


Reducing HE  
tails

Beam Energy  
Impact


Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

## Old DUSEL design



## add plug



Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

# Summary and Conclusions



# Summary - improved performance

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

Signal type	Old oa flux	New focusing	With plug
$\nu_e$ signal $\delta_{cp}=+45$	295	403	393
$\nu_e$ signal $\delta_{cp}=0$	395	538	525
$\nu_e$ signal $\delta_{cp}=-45$	509	683	669
NC bkgd	202	273	224
beam $\nu_e$ bkgd	196	227	253
numu	15	15?	15

**Flux in the signal region by 30% compared to previous designs**

- Used NuMI horns (known performance) and optimized current and alignment for DUSEL beam.
- Fully embedded target into Horn 1
- Increased horn current from 185kA (current NuMI) to 250kA.

# Summary - lowering backgrounds

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

**HE tails contribute 50-60% of NC background for  $\nu_e$  appearance**

## HE tail ( $> 5$ GeV) adjustments to Fluka05 MC

Adjustment	Effect	Comment
MINOS beam fit (Data)	$\sim +20\%$	10% more flux at $< 5$ GeV
He in beampipe (Data)	$+3\%$	different beampipe geometry
1.5 m graphite plug (MC)	$-38\%$	LE unchanged
$0.5^\circ$ off-axis (MC)	$-38\%$	Less coverage at 1st maxima
p-beam $120 \rightarrow 60$ GeV	$-46\%^{**}$	At the same power

**\*\* Estimated using AGS focusing not NuMI**

**With 120 GeV protons, plug is the best option for lowering HE tails**

# Whats next?

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

- **Optimize beam energy in the range 90-120GeV**
- **Waiting for results of MINOS efforts to model He in decay pipe using Fluka08 to finish He study.**
- **Continue study tunability of plugs - should we have a plug moves along the beam axis? Early studies indicate this changes where the cutoff in energy starts.**
- **Move horns even closer?**
- **Target material and geometry optimization (Jim Hylen & Byron Lundberg)**
- **After Byron and Jim agree on a beam pipe shape - put all effects in MC: MINOS ND data corrections, correct target material, He in beam pipe, best plug and/or off-axis angle, decay pipe optimized to reduce volume. RECALCULATE SENSITIVITIES.**
- **Suggestions, please?**

# Breakdown of NuMI spectrum

Zarko Pavlovich

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization


Decay Pipe  
Optimization

Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions



**High energy  $\nu$  come from hadrons exiting horn 1 on-axis**

Optimization  
of the DUSEL  
Beam Design

Mary Bishai  
Brookhaven  
National Lab

Motivation

Focusing  
system  
optimization

Decay Pipe  
Optimization




Reducing HE  
tails

Beam Energy  
Impact

Physics  
impact of  
latest beam  
designs

Summary and  
Conclusions

The MiniBoone detector is located at an angle of 110mrad off-axis from the NuMI beam 745m downstream of the NuMI target.



**First measurement of an off-axis beam - good agreement with prediction**